

2019 Lead Testing Results											
School	Date	Sample Taken By:	Estimate of Standing Period hh:mm	Sample	Time	Sample Area	Sample	Results ug/L	Date Results Rec'd	Follow-up Action as per Public Health Unit	
ADHS	20-Oct-20	Beth MacLean	6:35	S	5:30	Café kitchen, food prep tap	S	0.003	6-Nov-20	n/a	
sample unfiltered tap	20-Oct-20	Beth MacLean		F	6:15	Café kitchen, food prep tap	F	<0.001	6-Nov-20		
Arnprior Con Ed	Co-located in ADHS										
Admaston	21-Oct-20	Dennis Verdon	11:00	S	6:30	Room 129 Kinder sink 2	S	<0.001	6-Nov-20	n/a	
	21-Oct-20	Dennis Verdon		F	7:17	Room 129 Kinder sink 2	F	<0.001	6-Nov-20		
A.J. Charbonneau	30-Sep-20	Jen Hartwick	6:45	S	4:00	Rm 152, Tap 2 Kinderroom	S	<0.001	16-Oct-20	n/a	
	30-Sep-20	Jen Hartwick		F	4:45	Rm 152, Tap 2 Kinderroom	F	<0.001	16-Oct-20		
Beachburg	27-Oct-20	Rona Lee McCrea	10:00	S	6:30	Kinder Room 106	S	<0.001	6-Nov-20	n/a	
	27-Oct-20	Rona Lee McCrea		F	7:15	Kinder Room 106	F	<0.001	6-Nov-20		
Central	22-Oct-20	Lawrence Hisko	9:55	S	6:25	Rm 127 Kinder	S	0.002	6-Nov-20	n/a	
	22-Oct-20	Lawrence Hisko		F	7:10	Rm 127 Kinder	F	0.002	6-Nov-20		
Champlain Discovery	01-Oct-20	Steve Liedtke	6:40	S	6:30	Room 123 Tap 1	S	<0.001	26-Oct-20	n/a	
	01-Oct-20	Steve Liedtke		F	7:15	Room 123 Tap 1	F	0.002	26-Oct-20		
Cobden	21-Oct-20	Carina Wuehr	6:44	S	6:45	Room 4, Tap 2	S	<0.001	6-Nov-20	n/a	
	21-Oct-20	Carina Wuehr		F	7:32	Room 4, Tap 2	F	<0.001	6-Nov-20		
Eganville	07-Oct-20	Clinton Kumm	6:30	S	6:00	Staff Room Tap	S	0.008	26-Oct-20	n/a	
	07-Oct-20	Clinton Kumm		F	6:45	Staff Room Tap	F	0.002	26-Oct-20		
Fellowes HS	14-Oct-20	Sherry Michaud	6:57	S	5:27	Café Kitchen, Tap 5	S	0.010	26-Oct-20	n/a	
	14-Oct-20	Sherry Michaud		F	6:12	Café Kitchen Tap 5	F	0.003	26-Oct-20		
Herman Street	02-Oct-20	Melissa Best	7:57	S	7:22	Room 2 Tap 1	S	13.000	14-Oct-20	Resample	
	02-Oct-20	Melissa Best		F	8:11	Room 2 Tap 1	F	11.000	14-Oct-20		
Herman Street	03-Nov-20	Paul Blake		S	7:00	Room 2 Tap 1	S	10.000	12-Nov-20	Daily Flushing to Continue	
	03-Nov-20	Paul Blake	Resample	F	7:46	Room 2 Tap 1	F	7.000	12-Nov-20	emailed custodian	
Highview	03-Oct-20	Steve Wood	8:50	S	7:50	Rm 303, Counter Tap	S	<0.001	26-Oct-20		
	03-Oct-20	Steve Wood		F	8:35	Rm 303, Counter Tap	F	<0.001	26-Oct-20		
Killaloe	01-Oct-20	Tony Yandernoll	9:40	S	5:40	Rm 120 Tap 1 Kinderroom	S	<0.001	16-Oct-20	n/a	
	01-Oct-20	Tony Yandernoll		F	6:26	Rm 120 Tap 1 Kinderroom	F	0.001	16-Oct-20		
Mackenzie CS	24-Oct-20	Craig Lance	9:00	S	9:00	Rm 1034A Kinder Tap 1	S	<0.001	6-Nov-20	n/a	
	24-Oct-20	Craig Lance		F	9:50	Rm 1034A Kinder Tap 1	F	<0.001	6-Nov-20		
Madawaska Valley DHS	04-Nov-20	Shelley Schruder	7:41	S	6:26	Rm 1030 Servery Prep Tap	S	0.007	12-Nov-20	n/a	
		Shelley Schruder		F	7:12	Rm 1030 Servery Prep Tap	F	0.003	12-Nov-20		
McNab	30-Sep-20	Donna McNulty	9:31	S	6:31	Rm 124	S	<0.001	16-Oct-20	n/a	
	30-Sep-20	Donna McNulty		F	7:20	Rm 124	F	<0.001	16-Oct-20		

2019 Lead Testing Results											
School	Date	Sample Taken By:	Estimate of Standing Period hh:mm	Sample	Time	Sample Area	Sample	Results ug/L	Date Results Rec'd	Follow-up Action as per Public Health Unit	
Opeongo HS	20-Oct-20	Paul Bromley	6:55	S	5:50	Rm 1022 Kitchen back tap	S	0.001	6-Nov-20	n/a	
	20-Oct-20	Paul Bromley		F	6:36	Rm 1022 Kitchen back tap	F	<0.001	6-Nov-20		
Palmer Rapids	21-Oct-20	Brenda Recoskie	11:15	S	7:00	Kinder Rm 125	S	0.001	6-Nov-20	n/a	
	21-Oct-20	Brenda Recoskie		F	7:45	Kinder Rm 125	F	<0.001	6-Nov-20		
Pine View	07-Oct-20	Tammy Lance	12:55	S	7:25	Rm 105 Tap 1, Kinder	S	45.000	23-Oct-20	Continue daily flushing	daily flushing since 2017
		Tammy Lance		F	8:15	Rm 105 Tap 1, Kinder	F	3.000	23-Oct-20		
Queen Elizabeth	24-Sep-20	Lori Rathwell	10:15	S	7:05	Room 11	S	0.002	14-Oct-20	n/a	
	24-Sep-20	Lori Rathwell		F	7:51	Room 11	F	<0.001	14-Oct-20		
Renfrew Collegiate	30-Sep-20	Bonnie Gauthier	7:07	S	5:57	Room 1162 Café Kitchen	S	0.005	16-Oct-20	n/a	
	30-Sep-20	Bonnie Gauthier		F	6:43	Room 1162 Café Kitchen	F	0.001	16-Oct-20		
Rockwood	30-Sep-20	Bridget Roesler	7:00	S	6:50	Kinder Room 1, Tap 1	S	<0.001	16-Oct-20	n/a	
	30-Sep-20	Bridget Roesler		F	7:36	Kinder Room 1, Tap 1	F	0.001	16-Oct-20		
Valour	03-Oct-20	Jack Lavallee	7:29	S	6:59	Room 110 Tap 1	S	<0.001	26-Oct-20		
	03-Oct-20	Jack Lavallee		F	7:47	Room 110 Tap 1	F	<0.001	26-Oct-20		
Walter Zadow	30-Sep-20	Valerie Storie	7:39	S	6:24	Kinder Room 23 Tap	S	214.000	14-Oct-20	Resample	
		Valerie Storie		F	7:10	Kinder Room 23 Tap	F	70.000	14-Oct-20		
Walter Zadow	21-Oct-20	Valerie Storie	7:15	S	5:55	Kinder Room 23 Tap	S	450.000	23-Oct-20	Shut off and investigate	Plumbing replaced
Resample		Valerie Storie	Resample	F	6:40	Kinder Room 23 Tap	F	25.000	23-Oct-20	replace plumbing or install filter and resample	
Walter Zadow	28-Oct-20	Valerie Storie	7:11	S	5:56	Kinder Room 23 Tap	S	210.000	5-Nov-20	Install filters	
Resample		Valerie Storie	Resample	F	6:43	Kinder Room 23 Tap	F	114.000	5-Nov-20	Installed filters Nov 10/20	
Walter Zadow	11-Nov-20	Valerie Storie	7:10	S	5:55	Kinder Room 23 Tap	S	<0.001	23-Nov-20	n/a	
Resample		Valerie Storie	Resample	F	6:41	Kinder Room 23 Tap	F	<0.001	23-Nov-20		
Barry's Bay PAL site	Closed										
Mary St. Ed. Centre	30-Sep-20	James Letourneau	7:35	S	6:35	Rm 211 Kitchen	S	0.002	16-Oct-20	n/a	
	30-Sep-20	James Letourneau		F	7:20	Rm 211 Kitchen	F	<0.001	16-Oct-20		