

2012 Lead Testing Results												
School	Date	Sample Taken By:	Estimate of Standing Period hh:mm	Sample	Time	Sample Area	Sample	Results mg/L	Date Results Rec'd	Follow-up Action as per PHI for 2011	In addition to this years results the following sites continue flushing until results clear 2 conseq years	Year adverse detected
ADHS	30-May-12	L. Riopelle	6:10	S	5:30	Cafeteria Kitchen	S	10.2	7-Jun-12	Continue daily flushing	Daily Flushing (filtration system)	
	30-May-12	L. Riopelle		F	6:16	Cafeteria Kitchen	F	3.42	7-Jun-12			
Admaston	30-May-12	D. Lamendeau	14:10	S	6:40	Staff Sink	S	0.78	7-Jun-12	n/a		
	30-May-12	D. Lamendeau		F	7:25	Staff Sink	F	1.68	7-Jun-12			
A.J. Charbonneau	30-May-12	B. MacLean	7:00	S	7:00	Kitchen sink	S	2.68	7-Jun-12	n/a		
	30-May-12	B. MacLean		F	7:45	Kitchen sink	F	3.28	7-Jun-12			
Beachburg	13-Jun-12	M. Moore	12:55	S	6:55	Rm 124	S	2.29	18-Jun-12	n/a		
	13-Jun-12	M. Moore		F	7:40	Rm 124	F	0.99	18-Jun-12			
Central	25-May-12	C. Kumm	10:30	S	6:30	Staff Room	S	0.60	7-Jun-12	n/a		
	25-May-12	C. Kumm		F	7:15	Staff Room	F	1.00	7-Jun-12			
Champlain Discovery	30-May-12	B. Schreader	7:10	S	6:40	Staff Room	S	1.65	14-Jun-12	n/a	Cleared can reduce to weekly flushing	2010
	30-May-12	B. Schreader		F	7:25	Staff Room	F	0.74	14-Jun-12			
Cobden	29-May-12	M. Lippert	13:06	S	7:06	Staff Rm Kitchen	S	2.55	7-Jun-12	n/a		
	29-May-12	M. Lippert		F	7:52	Staff Rm Kitchen	F	7.96	7-Jun-12			
Eganville	24-May-12	E. Doering	14:03	S	7:03	Staff Kitchen	S	4.34	7-Jun-12	na	Discontinue daily flushing in 2011/12	
	24-May-12	E. Doering		F	7:53	Staff Kitchen	F	1.59	7-Jun-12			
Fellowes HS	30-May-12	B. Lewis	11:00	S	8:00	Rm 148-Teaching Kitchen	S	0.21	21-Jun-12	n/a		
	30-May-12	B. Lewis		F	8:45	Rm 148-Teaching Kitchen	F	0.33	21-Jun-12			
General Lake	25-May-12	C. Cobus	6:35	S	6:05	Staffroom 2nd Floor	S	3.85	14-Jun-12	n/a	Daily Flushing	2011
	25-May-12	C. Cobus		F	6:50	Staffroom 2nd Floor	F	1.20	14-Jun-12			
General Panet HS	31-May-12	R. Remus	11:34	S	6:26	Cafeteria Kitchen	S	3.12	14-Jun-12	n/a	Daily Flushing	2011
	31-May-12	R. Remus		F	7:11	Cafeteria Kitchen	F	2.17	14-Jun-12			
Herman Street	8-Jun-12	B. Driscoll		S	6:58	School Counsellor Room	S	1.66	21-Jun-12	n/a	Daily Flushing	2009/10/11
	8-Jun-12	B. Driscoll		F	7:45	School Counsellor Room	F	5.49	21-Jun-12			
Highview	5-Jun-12	N. Godreau	7:30	S	6:30	Custodial Rm	S	0.75	14-Jun-12	n/a	Cleared can reduce to weekly flushing	2009/10
	5-Jun-12	N. Godreau		F	7:15	Custodial Rm	F	0.30	14-Jun-12			
Killaloe	30-May-12	D. Welk	12:15	S	5:30	Lunch Rm Kitchen - Treated UV & Chl	S	15.6	7-Jun-12	Continue daily flushing	Daily Flushing	2010/11
	30-May-12	D. Welk		F	6:15	Lunch Rm Kitchen - Treated UV & Chl	F	6.81	7-Jun-12			
	30-May-12	D. Welk	12:15	S	5:30	Lunch Rm Kitchen - UV Protected	S	1.73	7-Jun-12			
	30-May-12	D. Welk		F	6:15	Lunch Rm Kitchen - UV Protected	F	0.64	7-Jun-12			
Mackenzie HS	24-May-12	C. Lance	8:00	S	6:44	Cafeteria	S	0.40	7-Jun-12		Discontinue daily flushing 2011/12	
	24-May-12	C. Lance		F	7:31	Cafeteria	F	0.63	7-Jun-12			
Madawaska PS	31-May-12	P. Hilderbrandt	13:30	S	7:00	Kitchen	S	0.12	14-Jun-12	n/a		
	31-May-12	P. Hilderbrandt		F	7:46	Kitchen	F	0.05	14-Jun-12			
Madawaska Valley DHS	14-Jun-12	D. Brotton	6:50	S	5:50	Family Studies Kitchen	S	2.31	21-Jun-12	n/a	Discontinue daily flushing 2011/12	
	14-Jun-12	D. Brotton		F	6:35	Family Studies Kitchen	F	1.61	21-Jun-12			
McNab	25-May-12	V. Verdon	8:45	S	6:45	Staff Rm Kitchen	S	0.40	7-Jun-12	n/a		
	25-May-12	V. Verdon		F	7:30	Staff Rm Kitchen	F	1.12	7-Jun-12			
Opeongo	15-Jun-12	J. Boldt	7:25	S	6:25	Kitchen	S	15.00	26-Jun-12	Daily flushing	Daily Flushing	2012
	15-Jun-12	J. Boldt		F	7:12	Kitchen	F	1.93	26-Jun-12			
Palmer Rapids	14-Jun-12	F. Welk	15:30	S	7:30	Staff Room	S	1.17	21-Jun-12	n/a		
	14-Jun-12	F. Welk		F	8:20	Staff Room	F	1.26	21-Jun-12			
Pincrest	23-May-12	R. Meilleur	13:50	S	6:40	Fountain by Room #1	S	1.93	7-Jun-12	n/a	Daily Flushing	2011
	23-May-12	R. Meilleur		F	7:26	Fountain by Room #1	F	2.96	7-Jun-12			
Pine View	29-May-12	D. Goldberg	12:20	S	6:45	Rm 118	S	5.86	14-Jun-12	n/a	Daily Flushing	2011
	29-May-12	D. Goldberg		F	7:30	Rm 118	F	3.78	14-Jun-12			
Queen Elizabeth	29-May-12	D. Hamilton	10:57	S	7:02	Kitchen	S	1.27	7-Jun-12	n/a		
	29-May-12	D. Hamilton		F	7:51	Kitchen	F	3.50	7-Jun-12			
Renfrew Collegiate	30-May-12	MJ Curley	7:25	S	6:25	Rm 1383 Foods Rm Kitchen	S	0.65	7-Jun-12	n/a		
	30-May-12	MJ Curley		F	7:10	Rm 1383 Foods Rm Kitchen	F	1.49	7-Jun-12			
Rockwood	18-May-12	B. Roesler	9:31	S	7:01	Kitchen	S	3.05	7-Jun-12	n/a		
	18-May-12	B. Roesler		F	7:47	Kitchen	F	1.12	7-Jun-12			
Sherwood	30-May-12	P. Trebinskie	14:20	S	6:50	Kitchen	S	1.18	14-Jun-12	n/a	Discontinue daily flushing 2011/12	
	30-May-12	P. Trebinskie		F	7:35	Kitchen	F	0.57	14-Jun-12			
Walter Zadow	30-May-12	B. Code	6:45	S	6:15	Breakfast Club Kitchen	S	11.90	7-Jun-12	Continue daily flushing	Daily Flushing	2010/11
	30-May-12	B. Code		F	7:00	Breakfast Club Kitchen	F	7.00	7-Jun-12			
Westmeath	28-May-12	M. Tate	15:10	S	7:30	Staff Kitchen	S	3.22	7-Jun-12	n/a		
	28-May-12	M. Tate		F	8:20	Staff Kitchen	F	4.47	7-Jun-12			
Whitney PS	7-Jun-12	B. Lynch	12:00	S	7:10	Kitchen	S	2.33	18-Jun-12	n/a		
	7-Jun-12	B. Lynch		F	7:55	Kitchen	F	0.73	18-Jun-12			
New Horizons												
Renfrew Con't Ed	8-Jun-12	MJ Curley	16:00	S	7:30	Staff Room	S	0.24	18-Jun-12	n/a		
	8-Jun-12	MJ Curley		F	8:15	Staff Room	F	0.19	18-Jun-12			
Petawawa Con't Ed Site closing August 2012												
Arnprior PAL site	6-Jun-12	L. Riopelle	13:45	S	5:20	Kitchen	S	1.59	15-Jun-12	n/a		
	6-Jun-12	L. Riopelle		F	6:05	Kitchen	F	4.41	15-Jun-12			
Barry's Bay PAL site	6-Jun-12	D. Brotton	15:40	S	5:50	Main Kitchen	S	4.81	18-Jun-12	n/a	Daily Flushing	2011
	6-Jun-12	D. Brotton		F	6:37	Main Kitchen	F	1.74	18-Jun-12			
Mary St. Ed. Centre	23-May-12	N. Melancon	15:00	S	7:00	Staff Kitchen - 2nd floor	S	0.55	7-Jun-12	n/a	Daily Flushing	2011
	23-May-12	N. Melancon		F	7:45	Staff Kitchen - 2nd floor	F	9.22	7-Jun-12			