

2013 Lead Testing Results												
School	Date	Sample Taken By:	Estimate of Standing Period hh:mm	Sample	Time	Sample Area	Sample	Results mg/L	Date Results Rec'd	Follow-up Action as per PHI for 2013	In addition to this years results the following sites continue flushing until results clear 2 conseq years	Year adverse detected
ADHS	25-May-13	Lynn Riopelle	8:50	S	7:50	Cafeteria Kitchen	S			Continue daily flushing	Daily Flushing (filtration system)	
	25-May-13	Lynn Riopelle		F	8:36	Cafeteria Kitchen	F					
Admaston	12-Jun-13	Dale Lamendeau		S	6:30	Staffroom	S			n/a		
	12-Jun-13	Dale Lamendeau		F	7:16	Staffroom	F					
A.J. Charbonneau	28-May-13	Beth MacLean		S	6:50	Kitchen	S	0.003	19-Jun-13	n/a		
	28-May-13	Beth MacLean		F	7:35	Kitchen	F	<0.001	19-Jun-13			
Beachburg	21-Jun-13	Mike Moore		S	7:32	Rm 124	S			n/a		
	21-Jun-13	Mike Moore		F	8:17	Rm 124	F					
Central	29-May-13	Clinton Kumm	10:30	S	6:30	Staff Rm Kitchen	S	0.001	19-Jun-13	n/a		
	29-May-13	Clinton Kumm		F	7:15	Staff Rm Kitchen	F	<0.001	19-Jun-13			
Champlain Discovery	29-May-13	Bill Schreader	7:15	S	6:45	Staff Room	S	0.002	18-Jun-13	n/a		2010
	29-May-13	Bill Schreader		F	7:32	Staff Room	F	<0.001	18-Jun-13			
Cobden	28-May-13	M. Lippert		S	7:10	Staff Room Kitchen	S	0.005	18-Jun-13	n/a		
	28-May-13	M. Lippert		F	8:00	Staff Room Kitchen	F	0.001	18-Jun-13			
Eganville	29-May-13	Denis Verdon		S	6:50	Kitchen by Gym	S	<0.001	18-Jun-13	na	Discontinue daily flushing in 2011/12	
	29-May-13	Denis Verdon		F	7:35	Kitchen by Gym	F	<0.001	18-Jun-13			
Fellowes HS	28-May-13	Robert Meilleur	8:40	S	7:00	Freddies Café	S	0.008	18-Jun-13	n/a		
	28-May-13	Robert Meilleur		F	7:45	Freddies Café	F	0.001	18-Jun-13			
General Lake	24-May-13	Connie Cobus		S	6:35	Room 27	S	0.003	18-Jun-13	n/a	Daily Flushing	2011
	24-May-13	Connie Cobus		F	7:20	Room 27	F	0.001	18-Jun-13			
General Panet HS	04-Jun-13	Robin Remus	8:28	S	6:28	Cafeteria Kitchen	S	0.005	18-Jun-13	n/a	Daily Flushing	2011
	04-Jun-13	Robin Remus		F	7:14	Cafeteria Kitchen	F	0.003	18-Jun-13			
Herman Street	29-May-13	Beverly Driscoll		S	7:45	Staff Kitchen Sink	S	0.029	18-Jun-13	Continue to flush daily	Daily Flushing	2009/10/11/13
	29-May-13	Beverly Driscoll		F	8:30	Staff Kitchen Sink	F	0.007	18-Jun-13			
Highview	29-May-13	Irene Mousseau	7:47	S	6:35	Custodial Kitchen - Rm 306	S	<0.001	18-Jun-13	n/a		2009/10
	29-May-13	Irene Mousseau		F	7:20	Custodial Kitchen - Rm 306	F	<0.001	18-Jun-13			
Killaloe	28-May-13	Doug Welk		S	5:30	UV Only - Lunch Rm Kitchen	S	0.002	19-Jun-13		Daily Flushing	2010/11/12/13
	28-May-13	Doug Welk		F	6:17	UV Only - Lunch Rm Kitchen	F	<0.001	19-Jun-13		Daily Flushing	
	28-May-13	Doug Welk		S	5:30	Chlorinated & UV - Lunch Rm Kitchen	S	0.019	19-Jun-13	Continue daily flushing	Daily Flushing	
	28-May-13	Doug Welk		F	6:17	Chlorinated & UV - Lunch Rm Kitchen	F	0.007	19-Jun-13		Daily Flushing	
Mackenzie CS	31-May-13	Craig Lance		S	6:50	Cafeteria	S	<0.001	17-Jun-13	n/a		
	31-May-13	Craig Lance		F	7:35	Cafeteria	F	<0.001	17-Jun-13			
Madawaska PS	06-Jun-13	P. Hildebrandt		S	6:30	Kitchen	S			n/a		
	06-Jun-13	P. Hildebrandt		F	7:20	Kitchen	F					
Madawaska Valley DHS	30-May-13	David Brotton		S	5:30	Kitchen C113	S	0.002	18-Jun-13	n/a		
	30-May-13	David Brotton		F	6:16	Kitchen C113	F	0.002	18-Jun-13			
McNab	28-May-13	Valerie Verdon		S	6:53	Kitchen	S	0.006	19-Jun-13	n/a		
	28-May-13	Valerie Verdon		F	7:38	Kitchen	F	0.004	19-Jun-13			
Opeongo	23-May-13	Joan Boldt	7:10	S	6:20	Kitchen	S	0.004	18-Jun-13	Daily flushing	Daily Flushing	2012
	23-May-13	Joan Boldt		F	7:05	Kitchen	F	0.002	18-Jun-13			
Palmer Rapids	06-Jun-13	Flyod Welk	15:04	S	7:19	Kitchen	S			n/a		
	06-Jun-13	Flyod Welk		F	8:04	Kitchen	F					
Pinecrest	12-Jun-13	Debbie Goldberg	7:20	S	6:35	Staffroom	S			n/a	Daily Flushing	2011
	12-Jun-13	Debbie Goldberg		F	7:22	Staffroom	F					
Pine View	29-May-13	Noel Godreau	13:00	S	7:00	Rm 118	S	0.068	19-Jun-13	Resample required	Daily Flushing	2011
	29-May-13	Noel Godreau		F	7:45	Rm 118	F	0.012	19-Jun-13			
Queen Elizabeth	28-May-13	Darlene Hamilton		S	6:56	Kitchen	S	0.005	20-Jun-13	n/a		
	28-May-13	Darlene Hamilton		F	7:46	Kitchen	F	0.001	20-Jun-13			

