

2014 Lead Testing Results												
School	Date	Sample Taken By:	Estimate of Standing Period hh:mm	Sample	Time	Sample Area	Sample	Results mg/L	Date Results Rec'd	Follow-up Action as per PHI for 2013	In addition to this years results the following sites continue flushing until results clear 2 conseq years	Year adverse detected
ADHS	22-May-14	Lynn Riopelle	6:40	S	5:25	Cafeteria Kitchen	S	0.006	13-Jun-14		Daily Flushing (filtration system)	2012
	22-May-14	Lynn Riopelle		F	6:12	Cafeteria Kitchen	F	0.002				
Admaston	28-May-14	Dale Lamendeau	14:30	S	6:45	Staffroom	S	0.003	13-Jun-14			
	28-May-14	Dale Lamendeau		F	7:30	Staffroom	F	0.004				
A.J. Charbonneau	27-May-14	Denis Verdon	7:00	S	6:30	Kitchen	S	0.002	13-Jun-14			
	27-May-14	Denis Verdon		F	7:15	Kitchen	F	<0.001				
Beachburg	27-May-14	Mike Moore	14:10	S	7:40	Rm 124	S	0.003	18-Jun-14			
	27-May-14	Mike Moore		F	8:26	Rm 124	F	0.001				
Central	27-May-14	Paul Bromley	10:45	S	6:35	Breakfast Room	S	0.003	19-Jun-14			
	27-May-14	Paul Bromley		F	7:20	Breakfast Room	F	0.002				
Champlain Discovery	28-May-14	Bill Schreader	7:00	S	6:45	Staff Room	S	<0.001	13-Jun-14			2010
	28-May-14	Bill Schreader		F	7:30	Staff Room	F	<0.001				
Gobden	27-May-14	Irene Mousseau	9:15	S	7:15	Staff Rm Main Floor	S	0.005	18-Jun-14			
	27-May-14	Irene Mousseau		F	8:00	Staff Rm Main Floor	F	0.002				
Eganville	27-May-14	Clinton Kumm	6:00	S	5:30	Staff Rm Kitchen	S	0.002	13-Jun-14			
	27-May-14	Clinton Kumm		F	6:15	Staff Rm Kitchen	F	<0.001				
Fellowes HS	27-May-14	Robert Meilleur		S	6:50	Teaching Kitchen	S	<0.001	13-Jun-14			
	27-May-14	Robert Meilleur		F	7:35	Teaching Kitchen	F	<0.001				
General Lake PS	15-Aug-14	Mike O'Malley		S	6:03	Rm 27	S	0.009	26-Aug-14			2011
	15-Aug-14	Mike O'Malley		F	7:00	Rm 27	F	0.002				
General Panet HS	15-Aug-14	Robin Remus		S	6:40	Cafeteria Kitchen	S	0.007	26-Aug-14			2011
	15-Aug-14	Robin Remus		F	7:25	Cafeteria Kitchen	F	0.005				
Herman Street	28-May-14	Paula Molloy	8:50	S	7:50	Staff Rm Kitchen	S	0.037	26-Jun-14	Resample	Daily Flushing	2009/10/11/13/14
	28-May-14	Paula Molloy		F	8:35	Staff Rm Kitchen	F	0.044				
	27-Jun-14	Paula Molloy	9:37	S	7:37	Custodial Room	S	0.043	16-Jul-14	Resample		
	27-Jun-14	Paula Molloy		F	8:25	Custodial Room	F	0.050				
	18-Jul-14	Noel Godreau	15:05	S	6:55	Custodial Room	S	4.440	30-Jul-14	Resample in area /Reg		
	18-Jul-14	Noel Godreau		F	7:40	Custodial Room	F	0.170				
	06-Aug-14	Bill Murray	8:17	S	11:17	Kitchen	S	0.018	18-Aug-14	Continue daily flushing		
	07-Aug-14			F	12:04	Kitchen	F	0.007				
Highview	27-May-14	Rona Lee McCrea	7:47	S	6:35	Gym Kitchen	S	0.011		Continue daily flushing	Daily Flushing	2014
	27-May-14	Rona Lee McCrea		F	7:20	Gym Kitchen	F	0.006				
Killaloe	28-May-14	Doug Welk	13:30	S	5:30	UV Protected - Lunch Rm Kitchen	S	0.002	26-Jun-14		Daily Flushing	2010/11/12/13/14
	28-May-14	Doug Welk		F	6:17	UV Protected - Lunch Rm Kitchen	F	<0.001				
	28-May-14	Doug Welk	13:30	S	5:30	Chlorinated - Lunch Rm Kitchen	S	0.028		Continue daily flushing		
	28-May-14	Doug Welk		F	6:17	Chlorinated - Lunch Rm Kitchen	F	0.008				
Mackenzie CS	29-May-14	Craig Lance	7:35	S	6:35	Cafeteria Kitchen	S	<0.001	13-Jun-14			
	29-May-14	Craig Lance		F	7:22	Cafeteria Kitchen	F	<0.001				
Madawaska PS	29-May-14	P. Hildebrandt	13:35	S	6:35	Kitchen	S	<0.001	13-Jun-14			
	29-May-14	P. Hildebrandt		F	7:20	Kitchen	F	<0.001				
Madawaska Valley DHS	04-Jun-14	David Brotton		S	5:30	Kitchen C113	S	0.002	13-Jun-14			
	04-Jun-14	David Brotton		F	6:15	Kitchen C113	F	0.001				
McNab	22-May-14	Valerie Verdon	8:48	S	6:15	Kitchen	S	0.003	19-Jun-14			
	22-May-14	Valerie Verdon		F	7:00	Kitchen	F	0.002				
Opeongo	28-May-14	Madeleine Lippert	7:30	S	6:30	Kitchen	S	0.003	19-Jun-14		Daily Flushing	2012
	28-May-14	Madeleine Lippert		F	7:16	Kitchen	F	0.001				
Palmer Rapids	29-May-14	Floyd Welk	14:50	S	7:20	Staff Room	S	0.002	13-Jun-14			
	29-May-14	Floyd Welk		F	8:06	Staff Room	F	<0.001				

2014 Lead Testing Results												
School	Date	Sample Taken By:	Estimate of Standing Period hh:mm	Sample	Time	Sample Area	Sample	Results mg/L	Date Results Rec'd	Follow-up Action as per PHI for 2013	In addition to this years results the following sites continue flushing until results clear 2 conseq years	Year adverse detected
Pinecrest	15-Aug-14	Mike O'Malley		S	4:50	Hall Fountain by Rm #5	S	0.003	26-Aug-14		Daily Flushing	2011/2013
	15-Aug-14	Mike O'Malley		F	5:50	Hall Fountain by Rm #5	F	<0.001				
Pine View	28-May-14	Noel Godreau	13:28	S	7:23	Kitchen	S	0.011	19-Jun-14	Continue daily flushing	Daily Flushing	2011-12-13-14
	28-May-14	Noel Godreau		F	8:08	Kitchen	F	0.004				
Queen Elizabeth	28-May-14	Darlene Hamilton	10:57	S	6:57	Kitchen	S	0.005	19-Jun-14			
	28-May-14	Darlene Hamilton		F	7:43	Kitchen	F	0.005				
Renfrew Collegiate	28-May-14	Brenda Code	7:20	S	6:20	Staff Room	S	0.001	13-Jun-14			
	28-May-14	Brenda Code		F	7:05	Staff Room	F	<0.001				
Rockwood	22-May-14	Sherry Michaud	7:58	S	6:58	Staff Kitchen	S	0.003	19-Jun-14			
	22-May-14	Sherry Michaud		F	7:43	Staff Kitchen	F	0.001				
Sherwood	12-Jun-14	Paul Trebinski	14:35	S	7:05	Staff Room	S	0.001	26-Jun-14			
	12-Jun-14	Paul Trebinski		F	7:51	Staff Room	F	<0.001				
Walter Zadow	11-Jun-14	Beth MacLean	7:07	S	6:32	Kitchen	S	0.015	19-Jun-14	Continue daily flushing	Daily Flushing	2010/11/12/13/14
	11-Jun-14	Beth MacLean		F	7:17	Kitchen	F	0.009				
Westmeath	27-May-14	Steve Liedtke	15:05	S	7:55	Conf. Room	S	<0.001	19-Jun-14			
	27-May-14	Steve Liedtke		F	8:40	Conf. Room	F	<0.001				
Whitney PS	05-Jun-14	Bart Lynch	13:20	S	7:05	Kitchen	S	<0.001	26-Jun-14			
	05-Jun-14	Bart Lynch		F	7:55	Kitchen	F	<0.001				
New Horizons											Site closure June 2014	
Renfrew Con't Ed	04-Jun-14	Bonnie Gauthier	15:15	S	7:00	Kitchen	S	<0.001	13-Jun-14			
	04-Jun-14	Bonnie Gauthier		F	7:45	Kitchen	F	<0.001				
Petawawa Con't Ed											No sampling req'd (Over 18 avg)	
Arnprior PAL site	23-May-14	Lynn Riopelle	13:40	S	5:15	Kitchen	S	0.007	13-Jun-14			2011
	23-May-14	Lynn Riopelle		F	6:01	Kitchen	F	0.003				
Barry's Bay PAL site	31-Jul-14	David Brotton	13:20	S	5:50	Kitchen	S	0.014	18-Aug-14	daily flushing	Daily Flushing	2014
	31-Jul-14	David Brotton		F	6:35	Kitchen	F	0.003	18-Aug-14			
Mary St. Ed. Centre	27-Jun-14	Sherry Michaud	10:40	S	6:10	Staff Kitchen	S	0.035	16-Jul-14		Samples results were reversed by lab resample taken anyway as a precaution.	2011
	27-Jun-14	Sherry Michaud		F	6:55	Staff Kitchen	F	0.001	16-Jul-14			
	24-Jul-14	Sherry Michaud		S	7:03	Staff Kitchen	S	0.004	30-Jul-14		Weekly flushing ok'd/C.DesRochers MOE	
	24-Jul-14	Sherry Michaud		F	7:50	Staff Kitchen	F	0.001	30-Jul-14			