

Client: ADMASTON PUBLIC SCHOOL  
182 Stone Rd.  
Renfrew, ON  
K7V 3Z5  
Attention: Ms. Paula Vanhoof  
PO#: 6071346759  
Invoice to: Renfrew County District School Board

Report Number: 1609279  
Date Submitted: 2016-06-08  
Date Reported: 2016-06-13  
Project: Admaston  
COC #: 808551  
Waterworks/Facility: 260013767


Page 1 of 3

---

**Dear Paula Vanhoof:**

**Please find attached the analytical results for your samples. If you have any questions regarding this report, please do not hesitate to call (613-727-5692).**

Report Comments:

 Shyla Monette  
2016.06.13  
11:06:09  
-04'00'

APPROVAL: \_\_\_\_\_

Shyla Monette  
Team Leader, Inorganics

All analysis is completed in Ottawa, Ontario (unless otherwise indicated).

Exova Ottawa is accredited by CALA, Canadian Association for Laboratory Accreditation to ISO/IEC 17025 for tests which appear on our CALA scope of accreditation. It can be found at <http://www.cala.ca/scopes/2602.pdf>.

Exova (Ottawa) is certified and accredited for specific parameters by OMAFRA, Ontario Ministry of Agriculture, Food and Rural Affairs (for farm soils). Licensed by Ontario MOE for specific tests in drinking water.

Exova (Mississauga) is accredited for specific parameters by SCC, Standards Council of Canada (to ISO 17025)

Please note: Field data, where presented on the report, has been provided by the client and is presented for informational purposes only. Guideline values listed on this report are provided for ease of use (informational purposes) only. Exova recommends consulting the official provincial or federal guideline as required.

Client: ADMASTON PUBLIC SCHOOL  
 182 Stone Rd.  
 Renfrew, ON  
 K7V 3Z5  
 Attention: Ms. Paula Vanhoof  
 PO#: 6071346759  
 Invoice to: Renfrew County District School Board

Report Number: 1609279  
 Date Submitted: 2016-06-08  
 Date Reported: 2016-06-13  
 Project: Admaston  
 COC #: 808551  
 Waterworks/Facility: 260013767

Group	Analyte	MRL	Units	Guideline	Lab I.D. Sample Matrix Sample Type Sampling Date Sample I.D.	1244288 Supply Water TREATEDWATER 2016-06-07 RM#4	1244289 Supply Water TREATEDWATER 2016-06-07 Staff Rm
AWQI Report	AWQI Report						129753
General Chemistry	Fluoride	0.10	mg/L	MAC-1.5			0.79
	Nitrate	0.10	mg/L	MAC-10.0		<0.10	
	Nitrite	0.10	mg/L	MAC-1.0		<0.10	
	Nitrite + Nitrate	0.10	mg/L	MAC-10.0		<0.10	
Metals	Sodium	2	mg/L	MAC-20			167*

**Guideline = MOE REG. 170/03**

**\* = Guideline Exceedence**

All analysis completed in Ottawa, Ontario (unless otherwise indicated by \*\* which indicates analysis was completed in Mississauga, Ontario).

Results relate only to the parameters tested on the samples submitted.

Methods references and/or additional QA/QC information available on request.

MRL = Method Reporting Limit, AO = Aesthetic Objective, OG = Operational Guideline, MAC = Maximum Acceptable Concentration, IMAC = Interim Maximum Acceptable Concentration, STD = Standard, PWQO = Provincial Water Quality Guideline, IPWQO = Interim Provincial Water Quality Objective, TDR = Typical Desired Range

Client: ADMASTON PUBLIC SCHOOL  
 182 Stone Rd.  
 Renfrew, ON  
 K7V 3Z5  
 Attention: Ms. Paula Vanhoof  
 PO#: 6071346759  
 Invoice to: Renfrew County District School Board

Report Number: 1609279  
 Date Submitted: 2016-06-08  
 Date Reported: 2016-06-13  
 Project: Admaston  
 COC #: 808551  
 Waterworks/Facility: 260013767

**QC Summary**

Analyte	Blank	QC % Rec	QC Limits
<b>Run No</b> 309457 <b>Analysis/Extraction Date</b> 2016-06-09 <b>Analyst</b> NP			
<b>Method</b> C SM4500-FC			
F	<0.10 mg/L	98	90-110
<b>Run No</b> 309468 <b>Analysis/Extraction Date</b> 2016-06-09 <b>Analyst</b> NP			
<b>Method</b> C SM4500-NO3-F			
N-NO2	<0.10 mg/L	100	80-120
N-NO3	<0.10 mg/L	90	80-120
NO2 + NO3 as N	<0.10 mg/L	94	80-120
<b>Run No</b> 309513 <b>Analysis/Extraction Date</b> 2016-06-10 <b>Analyst</b> SKH			
<b>Method</b> M SM3120B-3500C			
Sodium	<2 mg/L	102	82-118
<b>Run No</b> 309561 <b>Analysis/Extraction Date</b> 2016-06-10 <b>Analyst</b> C_P			
<b>Method</b> AWQI Report			
AWQI Report			

**Guideline = MOE REG. 170/03**

**\* = Guideline Exceedence**

All analysis completed in Ottawa, Ontario (unless otherwise indicated by \*\* which indicates analysis was completed in Mississauga, Ontario).  
 Results relate only to the parameters tested on the samples submitted.  
 Methods references and/or additional QA/QC information available on request.

MRL = Method Reporting Limit, AO = Aesthetic Objective, OG = Operational Guideline, MAC = Maximum Acceptable Concentration, IMAC = Interim Maximum Acceptable Concentration, STD = Standard, PWQO = Provincial Water Quality Guideline, IPWQO = Interim Provincial Water Quality Objective, TDR = Typical Desired Range