

2015 Lead Testing Results												
School	Date	Sample Taken By:	Estimate of Standing Period hh:mm	Sample	Time	Sample Area	Sample	Results mg/L	Date Results Rec'd	Follow-up Action as per PHI	In addition to this years results the following sites continue flushing until results clear 2 conseq years	Year exceedance detected
ADHS	20-May-15	Preflush	9:50-10:50								Daily Flushing (filtration system)	2012
	21-May-15	L. Riopelle	6:30	S	5:20	Cafeteria	S	0.007	9-Jun-15	Reduce to weekly	Reduce to weekly flushing-2 conseq years	
	21-May-15	L. Riopelle		F	6:05	Cafeteria	F	0.003	9-Jun-15			
Admaston	09-Jun-15	Preflush	3:30-4:30									
	10-Jun-15	D. Lamendeau	14:15	S	6:45	Staff Rm	S	0.001	24-Jun-15	N/A		
	10-Jun-15	D. Lamendeau		F	7:30	Staff Rm	F	<0.001	24-Jun-15			
A.J. Charbonneau	25-May-15	Preflush	11:00-12:00pm									
	26-May-15	D. Verdon	6:40	S	6:40	Kitchen Rm 127	S	0.002	9-Jun-15	N/A		
	26-May-15	D. Verdon		F	7:25	Kitchen Rm 127	F	<0.001	9-Jun-15			
Beachburg	26-May-15	Preflush	5:40 - 6:40									
	27-May-15	M. Moore	12:00	S	6:40	Rm 124	S	0.002	9-Jun-15	N/A		
	27-May-15	M. Moore		F	7:25	Rm 124	F	<0.001	9-Jun-15			
Central	25-May-15	Preflush	7:20-8:20									
	26-May-15	P. Bromley	9:40	S	6:00	Kitchen	S	<0.001	9-Jun-15	N/A		
	26-May-15	P. Bromley		F	6:47	Kitchen	F	<0.001	9-Jun-15			
Champlain Discovery	26-May-15	Preflush	10:30-11:50									2010
	27-May-15	B. Schreader	7:06	S	6:56	Staff Rm 165	S	0.002	9-Jun-15	N/A		
	27-May-15	B. Schreader		F	7:42	Staff Rm 165	F	0.003	9-Jun-15			
Cobden	16-Jun-15	Preflush	10:19-11:19									
	17-Jun-15	V. White	7:36	S	6:55	Staff Kitchen	S	0.005	24-Jun-15	N/A		
	17-Jun-15	V. White		F	7:42	Staff Kitchen	F	0.001	24-Jun-15			
Eganville	27-May-15	Pre-flush	10:30-11:30									
	28-May-15	C. Kumm	6:30	S	6:00	Staff Room	S	0.002	15-Jun-15	N/A		
	28-May-15	C. Kumm		F	6:45	Staff Room	F	<0.001	15-Jun-15			
Fellowes HS	25-May-15	Pre-flush	9:55-10:55									
	26-May-15	R. Meilleur	7:35	S	6:30	Hospitality Rm 148	S	<0.001	9-Jun-15	N/A		
	26-May-15	R. Meilleur		F	7:15	Hospitality Rm 148	F	<0.001	9-Jun-15			
Herman Street	28-May-15	Pre-flush	10:55-11:55								Daily Flushing	2009/10/11/13/14/15
	29-May-15	J. Hartwick	6:40	S	6:35	Kitchen	S	0.017	12-Jun-15	Continue daily flush		
	29-May-15	J. Hartwick		F	7:20	Kitchen	F	0.003	12-Jun-15			
Highview	21-May-15	Preflush	10:00-11:00								Daily Flushing	2014
	22-May-15	S. Liedtke	7:35	S	6:35	Staff Rm Sink	S	<0.001	9-Jun-15	Continue daily flush		
	22-May-15	S. Liedtke		F	7:20	Staff Rm Sink	F	<0.001	9-Jun-15			
Killaloe	09-Jun-15	Pre-flush	7:55-8:55								Daily Flushing	2010/11/12/13/14
	10-Jun-15	P. Trebinskie	8:35	S	5:30	Staff Kitchen	S	0.002	24-Jun-15	Continue daily flush		
	10-Jun-15	P. Trebinskie		F	6:16	Staff Kitchen	F	0.003	24-Jun-15			
	10-Jun-15	P. Trebinskie		S	5:30	Daycare Kitchen	S	0.003	24-Jun-15			
	10-Jun-15	P. Trebinskie		F	6:16	Daycare Kitchen	F	0.002	24-Jun-15			
Mackenzie CS	27-May-15	Preflush	10:20-11:20									
	28-May-15	C. Lance	7:15	S	6:35	Cafeteria Kitchen	S	<0.001	15-Jun-15	N/A		
	28-May-15	C. Lance		F	7:20	Cafeteria Kitchen	F	<0.001	15-Jun-15			
Madawaska PS	27-May-15	Pre-flush	4-5:00									
	28-May-15	P. Hilderbrandt	13:30	S	6:30	Kitchen	S	<0.001	15-Jun-15	N/A		
	28-May-15	P. Hilderbrandt		F	7:16	Kitchen	F	<0.001	15-Jun-15			

2015 Lead Testing Results												
School	Date	Sample Taken By:	Estimate of Standing Period hh:mm	Sample	Time	Sample Area	Sample	Results mg/L	Date Results Rec'd	Follow-up Action as per PHI	In addition to this years results the following sites continue flushing until results clear 2 conseq years	Year exceedance detected
Madawaska Valley DHS	27-May-15	Pre-Flush	10-11:00									
	28-May-15	D. Brotton		S	5:40	Kitchen Rm C113	S	0.002	9-Jun-15	N/A		
	28-May-15	D. Brotton		F	6:27	Kitchen Rm C113	F	0.002	9-Jun-15			
McNab	26-May-15	Preflush	7:52 - 8:54									
	27-May-15	V. Verdon	9:26	S	6:20	Kitchen	S	0.001	9-Jun-15	N/A		
	27-May-15	V. Verdon		F	7:05	Kitchen	F	<0.001	9-Jun-15			
Opeongo HS	26-May-15	Preflush	10:00-11:00									
	27-May-15	M. Lippert	7:04	S	6:04	Kitchen (Rm 1022)	S	0.002	9-Jun-15	Decrease to weekly	Decrease to weekly flush- 2 yr conseq	2012
	27-May-15	M. Lippert		F	6:51	Kitchen (Rm 1022)	F	<0.001	9-Jun-15			
Palmer Rapids	17-Jun-15	Preflush	3:30-4:30									
	18-Jun-15	F. Welk	14:45	S	7:15	Staff Rm Kitchen	S	<0.001	24-Jun-15	N/A		
	18-Jun-15	F. Welk		F	8:01	Staff Rm Kitchen	F	<0.001	24-Jun-15			
Pine View	03-Jun-15	Pre-flush	7:10-8:10								Daily Flushing	2011-12-13-14
	04-Jun-15	J. Hartwick	10:20	S	6:30	Staff Rm Kitchen	S	<0.001	15-Jun-15	Continue daily flushing		
	04-Jun-15	J. Hartwick		F	7:15	Staff Rm Kitchen	F	<0.001	15-Jun-15			
Queen Elizabeth	25-May-15	Preflush	6:55-7:55									
	26-May-15	D. Hamilton	12:00	S	6:55	Kitchen Rm 144	S	0.004	9-Jun-15	N/A		
	26-May-15	D. Hamilton		F	7:45	Kitchen Rm 144	F	0.001	9-Jun-15			
Renfrew Collegiate	26-May-15	Preflush	10-11:00									
	27-May-15	B. Code	7:05	S	6:05	Café Kitchen Rm 1025A	S	0.006	9-Jun-15	N/A		
	27-May-15	B. Code		F	6:50	Café Kitchen Rm 1025A	F	0.002	9-Jun-15			
Rockwood	28-May-15	Preflush	10:30-11:30									
	29-May-15	B. Roesler	7:35	S	7:05	Kitchen	S	0.002	15-Jun-15	N/A		
	29-May-15	B. Roesler		F	7:51	Kitchen	F	0.002	15-Jun-15			
Sherwood	27-May-15	Pre-flush	3:30-4:30									
	28-May-15	T. Yandernoll	14:30	S	7:00	Kitchen #3 - Staff Rm	S	0.001	9-Jun-15	N/A		
	28-May-15	T. Yandernoll		F	7:48	Kitchen #3 - Staff Rm	F	0.001	9-Jun-15			
Valour	02-Jun-15	Preflush	10:45-11:45									
	03-Jun-15	M. Best	6:12	S	5:57	Kitchen 1	S	0.002	15-Jun-15			
	03-Jun-15	M. Best		F	6:46	Kitchen 1	F	0.003	15-Jun-15			
Walter Zadow	26-May-15	Pre-flush	9:50-10:50								Daily Flushing	2010/11/12/13/14/15
	27-May-15	B. MacLean	7:40	S	6:30	Kitchen Rm 127	S	0.013	9-Jun-15	Continue daily flushing		
	27-May-15	B. MacLean		F	7:15	Kitchen Rm 127	F	0.007	9-Jun-15			
Westmeath	26-May-15	Pre-flush	2:50-3:55									
	27-May-15	M. Tate	15:00	S	6:55	Meeting Rm	S	<0.001	9-Jun-15	N/A		
	27-May-15	M. Tate		F	7:47	Meeting Rm	F	<0.001	9-Jun-15			
Whitney PS	27-May-15	Pre-flush	4:30-5:30									
	28-May-15	B. Lynch	13:30	S	7:00	Staff Rm	S	0.001	15-Jun-15	N/A		
	28-May-15	B. Lynch		F	7:45	Staff Rm	F	<0.001	15-Jun-15			
New Horizons	Located at Champlain DPS										Site closure June 2014	
Renfrew Con't Ed	26-May-15	Pre-flush	3-4:00									
	27-May-15	B. Gauthier	15:00	S	7:01	Kitchen Rm 5	S	<0.001	9-Jun-15	N/A		
	27-May-15	B. Gauthier		F	7:46	Kitchen Rm 5	F	<0.001	9-Jun-15			
Petawawa Con't Ed											No sampling req'd (Over 18 avg)	

2015 Lead Testing Results												
School	Date	Sample Taken By:	Estimate of Standing Period hh:mm	Sample	Time	Sample Area	Sample	Results mg/L	Date Results Rec'd	Follow-up Action as per PHI	In addition to this years results the following sites continue flushing until results clear 2 conseq years	Year exceedance detected
Arnprior PAL site	26-May-15	Pre-flush	14:00-15:00									2011
	27-May-15	L. Riopelle	14:11	S	5:10	Kitchen	S	0.008	9-Jun-15	N/A		
	27-May-15	L. Riopelle		F	5:56	Kitchen	F	0.004	9-Jun-15			
Barry's Bay PAL site	03-Jun-15	Pre-flush	1:30-2:30pm								Daily Flushing	2014
	04-Jun-15	D. Brotton	14:46	S	5:16	Kitchen	S	0.008	15-Jun-15	Continue daily flushing		
	04-Jun-15	D. Brotton		F	6:03	Kitchen	F	0.002	15-Jun-15			
Mary St. Ed. Centre	20-May-15	Pre-flush	3:53-4:56									2011
	21-May-15	J. Letourneau	13:45	S	6:41	Kitchen Rm 113A	S	0.003	9-Jun-15	Resample, begin daily flush	Daily Flushing	2015
	21-May-15	J. Letourneau		F	7:27	Kitchen Rm 113A	F	0.135	9-Jun-15			
Mary St. - Resample	10-Jun-15	Pre-flush	3:51-4:55									
	11-Jun-15	J. Letourneau	13:40	S	6:35	Kitchen Rm 113A	S	0.004	24-Jun-15	Flush daily, no resample needed		
	11-Jun-15	J. Letourneau		F	7:21	Kitchen Rm 113A	F	0.003	24-Jun-15			